

# Brazos Mutual Domestic Water Consumers Association

## Community Liaison Report

Submitted by: Chris Dennison

Reporting Period: December 2025

Report Date: December 22, 2025

### **Summary of Activities (December 2025)**

This report summarizes Community Liaison activities conducted during December 2025.

### **Water Tank Level Inspections**

Ten (10) water tank level inspections were completed. The lower storage tank remained stable. Improved delivery to the upper tank is anticipated after pump replacement at Well Houses 1 and 1A.

### **Random Meter Checks**

One (1) day of random meter checks was conducted on December 17, 2025 with no irregularities noted.

### **Leak Resolution – 30 Brook Lane**

The water line from the consumer-side shut-off valve to the residence was replaced. No further leaks were detected. The main meter is shut off for winter at the homeowner's request.

### **System Maintenance and Updates**

Electrical work at Well House Three has been completed. A failing pump at Well Houses One and One-A will be replaced in January 2026 by Richard Ulibarri.

### **Coordination and Technical Support**

David Romero with Rural Water will schedule a visit with system operators Levi Sandoval and Daniel Gonzales to review elevation valve operation.

### **Conclusion**

System operations remained stable throughout December 2025 with improvements scheduled for early 2026.

Submitted by:

Chris Dennison

Community Liaison

Brazos Mutual Domestic Water Consumers Association

# INVOICE

Brazos Mutual Domestic Water Consumers Association  
Attention: Board of Directors

From: Chris Dennison, Community Liaison

Invoice Date: December 22, 2025

Billing Period: December 2025

Description	Period Covered	Amount
Community Liaison Services	December 2025	\$350.00

**Total Due: \$350.00**

**Payable to:** Chris Dennison

**Mailing Address:**

HC 75 Box 161

Chama, NM 87520