

BRAZOS MUTUAL DOMESTIC WATER CONSUMERS ASSOCIATION

COMMUNITY LIAISON REPORT

July 2026

July was an active month for the continued evaluation, maintenance, and improvement of the water system. Several areas of the system were addressed, with a focus on increasing production, improving system reliability, and establishing a better understanding of overall water usage.

During the month, there were multiple visits and discussions with John Rector from NM Rural Water Association. His assistance and input have been valuable as we continue evaluating the system and identifying opportunities for improvement.

The PRV (Pressure Reducing Valve) was repaired during July. In addition, numerous system valves were reconfigured and adjusted in an effort to improve water flow and increase overall production. These adjustments will continue to be evaluated as we work to determine the most effective system configuration.

We also began reading meters at select homes. The purpose of these readings is to establish a baseline for water usage and help us better understand consumption patterns throughout the system. This information, along with continued observation and maintenance, will help guide future decisions regarding system operation and potential repairs.

Tank levels varied significantly throughout the month. On July 4, the tank level was just under 3 feet. By the end of July, the tank level had increased to just over 10 feet. These fluctuations continue to provide useful information as we evaluate well production, system demand, and overall system performance.

UPCOMING PLANS

Moving forward, our primary focus will include:

- Further evaluation of well production and capacity.
- Continued monitoring of tank levels and system performance.
- Ongoing evaluation and reconfiguration of system valves as needed.
- Continued meter readings to establish and refine water usage baselines.
- Identification and completion of necessary system maintenance and repairs.
- Continued coordination with NM Rural Water Association and other resources as appropriate.

We will continue to move forward with the evaluation, maintenance, and improvement of the water system. The information gathered during July will help provide a stronger foundation for

identifying problem areas, making informed adjustments, and developing a more reliable and sustainable system moving forward.