

BRAZOS MUTUAL DOMESTIC WATER CONSUMERS ASSOCIATION Community Liaison Report

Report Date: July 1, 2026 Activity Period: June 2026 Throughout June, multiple system inspections and random meter checks were conducted. A significant leak was discovered at 11 Cielo Azul and promptly reported. A damaged meter at 4 Falls Creek was repaired. The O-ring at the elevation valve was replaced to improve valve performance. Well 4 was brought online with some degree of success, although balancing production and consumption remains a challenge. Collaboration continued with John Rector of the New Mexico Rural Water Association and the Water Operator to troubleshoot the system and maximize available water. Despite these efforts, the low snowfall over the past two years is taking its toll on groundwater production. Continued conservation remains essential. Submitted By: Chris Dennison Community Liaison